

Severe Weather Louver ▲ 5" Deep ▲ Combination Stationary ▲ Chevron Blades ▲ Extruded Aluminum

STANDARD MATERIALS AND CONSTRUCTION

FRAME: .080" thk. (nominal) extruded aluminum, 6063-T52/T6 alloy.

BLADE: .063" thk. (nominal) extruded aluminum, 6063-T52/T6 alloy.
Horizontal blades approximately 1" on center (nominal),
vertical blades approximately 1 3/16" on center (nominal).

LOUVER FACE: Head and blades are contained within jambs, sill contains jambs.

SCREENS: (When indicated, in a removable frame.)

1/2" flattened aluminum (.051" thick),

-or- 1/2" sq. mesh, intermediate double-crimped aluminum wire, .063" dia.,

-or- 1 5/16 mesh, .011" dia. aluminum wire, insect screen.

DRAIN PAN: .060" thk. (nominal) formed aluminum with welded and caulked end dams.

FINISH: Mill

OPTIONS

Finish - Baked Enamel, Kynar, Anodized



NOTES

1. Nominal deductions will be made to the opening size given.
2. Louvers larger than the maximum factory assembled size will require field assembly of smaller louver sections.

LOUVER SIZES

Min Panel	Max Single Panel
12"W x 12"H	60"W x 96"H

This louver has been tested to **AMCA Standard 540 for Wind Borne Debris Impact Resistance** and **AMCA Standard 550 for High Velocity Wind Driven Rain**.
See Page 2 for seal and listing information.



Item #	Qty	Width	Height	Width	Height	Mullion	Type	Location	Union Made
		Opening Size		Louver Size			Screens		
Arch. / Eng. :						EDR:		ECN:	Job:
Contractor:									
Project:						Date:		DWN:	DWG:



Dampers ▲ Louvers
UL Life Safety Products
Division of Mestek
Member of AMCA

airbalance.com

In the interest of product development, Air Balance reserves the right to make changes without notice.
450 Riverside Dr • Wyalusing PA, 18853 • Phone 570-746-1888 • Fax 570-746-9286

Severe Weather Louver ▲ 5" Deep ▲ Combination Stationary ▲ Chevron Blades ▲ Extruded Aluminum

PERFORMANCE DATA



Pressure Drop: .47 in. wg at 1000 fpm

Free Area: 6.85 sq.ft. (43%) for 48"W x 48"H sample tested in accordance with AMCA Standard 500-L.

Beginning Point of Water Penetration: 821 fpm (5623 cfm)

Class "A" Rating with 100% efficiency at 3 in. rain fall at intake velocity of 1623 fpm (8,509 cfm) at wind speed of 29 mph.
 Class "A" Rating with 100% efficiency at 8 in. rain fall at intake velocity of 1420 fpm (7,444 cfm) at wind speed of 50 mph.
 Testing based on 48" x 48" based on AMCA Standard 500-L.

Ratings do not include effects of a screen.



Free Area (sq.ft.)

		Width (in.)								
		12"	18"	24"	30"	36"	42"	48"	54"	60"
Height (in.)	12"	.24	.39	.53	.68	.83	.97	1.12	1.26	1.41
	24"	.66	1.06	1.45	1.84	2.24	2.63	3.03	3.42	3.82
	36"	1.08	1.72	2.37	3.01	3.65	4.30	4.94	5.59	6.23
	48"	1.49	2.39	3.28	4.17	5.07	5.96	6.85	7.75	8.64
	60"	1.91	3.05	4.20	5.34	6.48	7.62	8.77	9.91	11.05
	72"	2.33	3.72	5.11	6.50	7.90	9.29	10.68	12.07	13.46
	84"	2.75	4.39	6.03	7.67	9.31	10.95	12.59	14.23	15.87
	96"	3.16	5.05	6.94	8.83	10.72	12.61	14.51	16.40	18.29

Severe Weather Louver ▲ 5" Deep ▲ Combination Stationary ▲ Chevron Blades ▲ Extruded Aluminum

Wind Driven Rainwater Penetration Test
Conducted to AMCA Standard 500-L.

Test size 1m x 1m (39.7" x 39.7") core area nominal.
Louver Free Area 5.24 square feet.

Core Ventilation (m/s)	0.0	0.5	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0	Rain Fall / MPH	
FPM	-	-	-	-	-	-	-	-	790	890	987	3 in. / hr. rain fall and 29 mph Velocity	
Free Area Ventilation (cfm)	-	-	-	-	-	-	-	-	8,509	9,577	10,623		
Free Area Velocity (fpm)	-	-	-	-	-	-	-	-	1623	1827	2026		
Effective Rating Class	A	A	A	A	A	A	A	A	A	A	B		
Effectiveness Ratio (%)	-	-	-	-	-	-	-	-	100	99.9	96.9		
FPM	-	-	-	-	-	-	-	-	691	791	889	8 in. / hr. rain fall and 50 mph Velocity	
Free Area Ventilation (cfm)	-	-	-	-	-	-	-	-	7,444	8,521	9,570		10,580
Free Area Velocity (fpm)	-	-	-	-	-	-	-	-	1420	1625	1825		2018
Effective Rating Class	A	A	A	A	A	A	A	A	A	A	B		
Effectiveness Ratio (%)	-	-	-	-	-	-	-	-	100	99.9	99.8		97.7

Wind Driven Rain Penetration Classifications

Class	Effectiveness %
A	100 to 99%
B	98.9% to 95%
C	94.9% to 80%
D	Below 80%

Discharge Loss Coefficient Classifications

Class	Discharge Loss Coefficient
1	0.4 and above
2	0.3 to 0.399
3	0.2 to 0.299
4	0.199 and below

Discharge Coefficient
Intake Cd = .17 (CLASS 4)

Class 1 Loss Coefficient has the least resistance to airflow.

1. Core area is the front opening of a louver assembly with the blades removed.
2. Core area velocity is the airflow rate through the louver divided by the core area (39.37" x 39.37").
3. Free area is the minimum area through which air can pass. It is determined by multiplying the sum of the minimum distance between intermediate blades, top blade and head, bottom blade and sill, by the minimum distance between jambs.
4. Discharge loss coefficient is calculated by dividing a louver actual airflow rate vs. a theoretical airflow for the opening, providing an indication of the louver air flow characteristics.



This label does not signify AMCA performance certification. See www.AMCA.org for all certified or listed products

Air Balance certifies that the Model A531 shown herein is approved to bear the AMCA Listing Label. The ratings shown are based on tests and procedures performed in accordance with AMCA Publications and comply with the requirements of the AMCA Listing Label Program.

The AMCA Listing Label applies to High Velocity Rain Resistant and Wind Borne Debris Impact Resistant Louvers.

Air Balance certifies that the Model A531 shown herein is licensed to bear the AMCA Seal. The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 511 and comply with the requirements of the AMCA Certified Ratings Program. The AMCA Certified Ratings Seal applies to Air Performance, Water Penetration, and Wind Driven Rain only.