Standard Materials and Construction

FRAME: Standard %" x 2" x %" extruded aluminum channel,

.080" thick (nominal).

BLADES: .060" thick (nominal) extruded aluminum.

SHAFT: 3/16" plated steel stub.

SEALS: Polyurethane foam at blade edges, none at jambs.

BEARINGS: 3/16" I.D. Oilite bronze.


Various types of bird and insect screens.


<u>Notes</u>

- 1. 1/4" nominal deduction will be made to the opening size given.
- 2. For counterweights, please specify airflow direction (horizontal, vertical up, or vertical down) and whether to the counterweight should assist or resist the damper opening.


Damper Sizes

Min Panel	Max Single Panel
12"W x 12"H	36"W x 72"H







Page 1



Optional Frames

Flanged Frame 2" or 4" Deep, .080" thk.





Item #	Qty	Width	Height	Width	Height	Mullion	Air Flow				NA DID
		Openi	ng Size	Damp	er Size	Mullion	(Direction)		(Direction)		<u>Union Made</u>
Arch. / Eng.:						EDR:		ECN:		Job:	
Conti	ractor:										
Project:						Date:		DWN:		DWG:	

19/16"

arrowunited.com