# MODEL EA-531-D

## Severe Weather Louver • 5" Deep • Combination Stationary • Chevron Blades • Extruded Aluminum

## Standard Materials and Construction

<u>siunuuru muter</u>	
FRAME:	.080" thk. (nominal) extruded aluminum, 6063-T52/T6 alloy.
BLADE:	.063" thk. (nominal) extruded aluminum, 6063-T52/T6 alloy.
	Horizontal blades approximately 1" on center (nominal),
	vertical blades approximately <sup>13</sup> / <sub>16</sub> " on center (nominal).
LOUVER FACE:	Head and blades are contained within jambs, sill contains
	jambs.
SCREENS:	(When indicated, in a removable frame.)
	1/2" flattened aluminum (.051" thick),
-or-	1/2" sq. mesh, intermediate double-crimped aluminum
	wire, .063" dia.,
-or-	<sup>18</sup> / <sub>16</sub> mesh, .011" dia. aluminum wire, insect screen.
DRAIN PAN:	.060" thk. (nominal) formed aluminum with welded and
	caulked end dams.
FINISH:	Mill
Options	

### <u>Options</u>


### Finish - Baked Enamel, Kynar, Anodized


### <u>Notes</u>

½" nominal deduction will be made to the opening size given.
Louvers larger than the maximum factory assembled size will require field assembly of smaller louver sections.

#### Louver Sizes

Min Panel	Max Single Panel	
12"W x 12"H	60"W x 96"H	
for Wind Borne Standard 550	s been tested to AN Debris Impact Resis D for High Velocity W 3 for seal and listing	stance and AMCA /ind Driven Rain.





Not to scale.

Item #	0.50	Width	Height	Width	Height	Mullion	Type Location				
iiem #	Qty	Opening Size		Louver Size		Mullion	Screens				<u>Union Made</u>
Arch.	/ Eng.:					EDR:		ECN:		Job:	
Cont	ractor:										
F	roject:					Date:		DWN:		DWG:	



In the interest of product development, Arrow United reserves the right to make changes without notice. 450 Riverside Dr • Wyalusing PA, 18853 • Phone 570-746-1888 • Fax 570-746-9286 AUI-09-02-13

## MODEL EA-531-D

Severe Weather Louver • 5" Deep • Combination Stationary • Chevron Blades • Extruded Aluminum


### Performance Data


Pressure Drop: .47 in. wg at 1000 fpm

Free Area: 6.85 sq.ft.( 43%) for 48"W x 48"H sample tested in accordance with AMCA Standard 500-L. Beginning Point of Water Penetration: 821 fpm (5623 cfm)

Class "A" Rating with 100% efficiency at 3 in. rain fall at intake velocity of 1623 fpm (8,509 cfm) at wind speed of 29 mph. Class "A" Rating with 100% efficiency at 8 in. rain fall at intake velocity of 1420 fpm (7,444 cfm) at wind speed of 50 mph. Testing based on 48" x 48" based on AMCA Standard 500-L.

### Ratings do not include effects of a screen.





			Free Area (sq.ft.)											
			Width (in.)											
		12"	18"	24"	30"	36"	42"	48"	54"	60"				
	12"	.24	.39	.53	.68	.83	.97	1.12	1.26	1.41				
	24"	.66	1.06	1.45	1.84	2.24	2.63	3.03	3.42	3.82				
· ·	36"	1.08	1.72	2.37	3.01	3.65	4.30	4.94	5.59	6.23				
it (in.)	48"	1.49	2.39	3.28	4.17	5.07	5.96	6.85	7.75	8.64				
Height	60"	1.91	3.05	4.20	5.34	6.48	7.62	8.77	9.91	11.05				
Ť	72"	2.33	3.72	5.11	6.50	7.90	9.29	10.68	12.07	13.46				
	84"	2.75	4.39	6.03	7.67	9.31	10.95	12.59	14.23	15.87				
	96"	3.16	5.05	6.94	8.83	10.72	12.61	14.51	16.40	18.29				



## MODEL EA-531-D

Severe Weather Louver • 5" Deep • Combination Stationary • Chevron Blades • Extruded Aluminum

Wind Driven Rainwater Penetration Test Conducted to AMCA Standard 500-L.

Test size 1m x 1m (39.7" x 39.7") core area nominal. Louver Free Area 5.24 square feet.

Core Ventilation (m/s)	0.0	0.5	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0	Rain Fall / MPH
FPM	-	-	-	-	-	-	-	-	790	890	987	
Free Area Ventilation (cfm)	-	-	-	-	-	-	-	-	8,509	9,577	10,623	3 in. / hr. rain fall
Free Area Velocity (fpm)	-	-	-	-	-	-	-	-	1623	1827	2026	and
Effective Rating Class	А	А	Α	Α	Α	Α	Α	A	Α	Α	В	29 mph Velocity
Effectiveness Ratio (%)	-	-	-	-	-	-	-	-	100	99.9	96.9	Velocity
FPM	-	-	-	-	-	-	-	691	791	889	983	
Free Area Ventilation (cfm)	-	-	-	-	-	-	-	7,444	8,521	9,570	10,580	8 in. / hr. rain fall
Free Area Velocity (fpm)	-	-	-	-	-	-	-	1420	1625	1825	2018	and
Effective Rating Class	А	А	Α	Α	Α	Α	Α	A	Α	А	В	50 mph Velocity
Effectiveness Ratio (%)	-	-	-	-	-	-	-	100	99.9	99.8	97.7	velocity

### Wind Driven Rain Penetration Classifications

Class	Effectiveness %
A	100 to 99%
В	98.9% to 95%
С	94.9% to 80%
D	Below 80%

#### **Discharge Loss Coefficient Classifications**

Class	Discharge Loss Coefficient
1	0.4 and above
2	0.3 to 0.399
3	0.2 to 0.299
4	0.199 and below

Discharge Coefficient

Intake Cd = .17 (CLASS 4)

Class 1 Loss Coefficient has the least resistance to airflow.

- 1. Core area is the front opening of a louver assembly with the blades removed.
- 2. Core area velocity is the airflow rate through the louver divided by the core area (39.37" x 39.37").
- 3. Free area is the minimum area through which air can pass. It is determined by multiplying the sum of the minimum distance between intermediate blades, top blade and head, bottom blade and sill, by the minimum distance between jambs.
- 4. Discharge loss coefficient is calculated by dividing a louver actual airflow rate vs. a theoretical airflow for the opening, providing an indication of the louver air flow characteristics.



Arrow United Industries certifies that the Model EA-531-D shown herein is approved to bear the AMCA Listing Label. The ratings shown are based on tests and procedures performed in accordance with AMCA Publications and comply with the requirements of the AMCA Listing Label Program.

The AMCA Listing Label applies to High Velocity Rain Resistant and Wind Borne Debris Impact Resistant Louvers.





Arrow United Industries certifies that the Model EA-531-D shown herein is licensed to bear the AMCA Seal. The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 511 and comply with the requirements of the AMCA Certified Ratings Program. The AMCA Certified Ratings Seal applies to Air Performance, Water Penetration, and Wind Driven Rain only.