


REVISIONS				
REV.	EN NO.	DATE	DRAWN BY	APPROVED
J	EN-0008-26	02/10/26	MAC	



LADDER DIAGRAM
120V 1Ø 60 Hz

DIVISION	PRODUCT	DRAWN BY	DATE	DRAWING DESCRIPTION			
ATH	KN-2 TO 4	RT	11/20/07	WIRING DIAGRAM, 120V, VER 3			
THE PRINT AND ALL INFORMATION THEREON IS PROPERTY OF THE DIVISION OF MESTEK, INC. NEITHER THE PRINT NOR THE INFORMATION THEREON MAY BE REPRODUCED OR USED IN ANY MANNER WHATSOEVER OR DIVULGED TO ANY OTHER PERSON UNLESS SPECIFICALLY AUTHORIZED BY MESTEK, INC.				CHECKED BY	DATE	DRAWING NUMBER	
				APPROVED BY	DATE	42-5801	
				SHEET	SHEET SIZE	SCALE	REVISION
				1 OF 2	B	N/A	J.01

D

D

C

C




B

B


A

A


COMMUNICATIONS DETAIL "A" (OPTIONAL)



THERMOSTAT TERMINALS ON ZONE CONTROLLER
NOTE: MEASURE VOLTAGE ON THE TERMINALS PRIOR TO MAKING ANY CONNECTIONS. TERMINAL HAVING 0 VOLTS MUST BE CONNECTED TO IAR TERMINAL (TYPICAL)



- NOTES:
- REMOVE JUMPER A WHEN USING THE WATER FLOW SWITCH OPTION. JUMPER B WHEN USING THE REMOTE HEAT DEMAND OPTION.
 - WIRE COLOR CODE SHALL BE AS FOLLOWS:
BK-BLACK GN-GREEN PK-PINK WT-WHITE
BL-BLUE GY-GRAY PR-PURPLE YL-YELLOW
BN-BROWN OR-ORANGE RD-RED
BK/YL-BLACK/YELLOW STRIPE GN/YL-GREEN/YELLOW
()-INDICATES WIRE FROM PURCHASED PART
 - ALL WIRES SHALL BE #18AWG UNLESS SPECIFIED. WIRE TYPE SHALL BE TEW, 600V, STRANDED 16X30, WITH INSULATION RATED FOR 105° OR EQUIVALENT. USE CABLE TIES, CABLE FASTENERS, SPADE TERMINALS, MALE CONNECTORS, WIRENUTS, ETC. AS REQUIRED.
 - USE CABLE TIES, CABLE FASTENERS, SPADE TERMINALS, MALE CONNECTORS, WIRENUTS, ETC. AS REQUIRED.
 - POWER SERVICE CIRCUIT PROTECTION DEVICE SUPPLIED BY CUSTOMER.
- WIRE CODE: — FACTORY WIRING - - - - OPTIONAL WIRING
- - - - FIELD WIRING - - - - DEVICE INTERNAL CONNECTION
- - - - WIRE HARNESS - - - - SHIELDED CABLE, MULTI-CONDUCTOR



CONNECTION DIAGRAM 120V 1Ø 60 Hz

DIVISION	ATH				
DRAWING DESCRIPTION	WIRING DIAGRAM, 120V, VER 3				
PRODUCT	KN-2 TO 4				
DRAWING NUMBER	42-5801				
SHEET	2 OF 2	SHEET SIZE	B	SCALE	N/A
REVISION	J.01				