



Torus Series Submittal Data Sheet (Models 1250 – 4000)

JOB NAME: _____

LOCATION: _____

ARCH/ENGR: _____

CONTRACTOR: _____

MODEL NO: _____

TYPE GAS: _____

BTU INPUT/OUTPUT: _____

ADDITIONAL INFORMATION:

Standard Features

- Up to 97.5% Boiler Efficiency
- Up to 98.0% Water Heater Efficiency
- Full Modulation with 10:1 turndown
- Stainless Steel Water Tube Heat Exchanger
- Painted Carbon Steel Jacket
- Relief Valve
- 7" Diagonal Touch Screen Display
- Tru-Flow™ Air Fuel Coupled System
- Flame Module Control
- Flame Rod Rectification
- Low Air Pressure Switch
- Manual Reset LWCO
- Condensate Drain
- Temperature/Pressure Gauge
- Low Gas Pressure Switch (2500-4000)
- High Gas Pressure Switch (2500-4000)
- Remote Local Switch
- Manual Reset High Limit
- Variable Speed Blower
- Flow Switch Mounted
- Air Vent
- Blocked Flue Switch
- Versatile Footprint Fits Through 36" Door (All Sizes)

Optional Equipment

- Dual Fuel Propane
- 208/230V 1PH ___ 3PH ___ (WB/WW2000) _____ V
- 208V 3PH (WB/WW2500-4000)
- 460/600V 3PH (WB/WW2000-4000) _____ V
- Common Header Supply Sensor 10K
- 3" Well
- Digital Flow Sensor
- Outdoor Sensor w/Enclosure 10K
- High Gas Pressure Switch (Manual Reset) (1250-2000)
- Low Gas Pressure Switch (Manual Reset) (1250-2000)
- Main Flame Status Contact
- Valve Proving Switch
- Freeze Protection Kit
- Motorized Valve/Wiring 120V Pwr Opn/Sprg Clsd
 Sprg Opn/Pwr Clsd Pwr Opn/Pwr Clsd
- Flue Outlet Damper/Wiring _____ V On/Off Mod
- Vent Termination Hood
- Air Intake Hood
- Pump (Shipped Loose)
- PVC Vent Kit
- PP Vent Kit
- BACnet ProtoCessor (MSTP)*
- BACnet ProtoCessor (IP)*
- LonWorks ProtoCessor*
- N2 ProtoCessor*

**HeatNet bridge addressing worksheet required.*

Gas Trains

- CSD-1
- IRI (Valve Proving System & CSD-1)
- FM
- KY Code

- HeatNet™ Control
 - Full Linear Modulation Control
 - Integrated Boiler Management System
 - Diagnostic Annunciator Touch Screen
 - 4-20 mA External Modulation Contact
 - Inlet/Outlet Temperature Sensors
 - Modbus Standard Protocol